



STATE OF WISCONSIN

Department of Safety and Professional Services

INDUSTRY SERVICES DIVISION

Administrator's Office

P. O. Box 2658

Madison, Wisconsin 53701-2658

Governor Scott Walker

Secretary Dave Ross

TTY: Contact Through Relay

Air Admittance Valves

SPS 382.31(3) - 11/19/97

Are air admittance valves approved in Wisconsin? The approval of specific air admittance valves is included among the product evaluations.

SPS 384.10(1) - 10/4/05

May air admittance valves be installed to serve chemical waste systems? No. If chemical resistant piping is installed to serve a fixture, an air admittance valve is not permitted as a vent termination.